

PROFOMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No- 01/24

Date: 08/02/2024

It is Certified that an inspection team headed by ...Beena Ambika... Chemist / Lab- Incharge
 (Name of officers with designation) from ... U.P. Jal Nigam (Rural)
 (Name of Department/ Office) Inspected the Water of Riverdale Global School, Jay Nagar
 (Name & Address of the School) on 08/02/24 (Date of inspection) and found that the
 Riverdale Global School, Jay Nagar (Name of school) has safe drinking water
 Facilities for the students and members of staff of the institution and is maintaining the hygienic
 sanitation condition in the school building & the campus as per norms prescribed by the
 central/State/ U.T. Govt.


The above is valid for a period of ..06.. Months

Signature with Seal:

Nam: Beena Ambika

Designation: Chemist / Lab- Incharge

Name & Address of the Office / Department: U.P. J.N. (R)



To

Riverdale Global School

Jay Nagar, Kundera, Ghazipur (U.P.)

Name & Address of the Institution)

*The filled up certificate should be either in Hindi or English. If It is issued in vernacular language. Translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Jal Jeevan Mission

Har Ghar Jal



Har Ghar Jal
Jal Jeevan Mission

District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Ghazipur

Office of Executive Engineer, Khand Karyalay, U.P Jal Nigam Rural, Ghazipur, pin 233001 (Test Address only)

Print

Test report

Sample ID: U708316516237230

User Information

Name: Sanjay Singh Yadav Mobile: 8840089203
Email: sanjayyadav611263@gmail.com Pin Code:
Full Address: Village- Not available, Gram Panchayat- Not available, Block- Not available, District- Ghazipur, State- Uttar Pradesh

Sample description

Source of Sample: Riverdal Global School, Jay Nagar, Kundesar, Ghazipur U.P Village: Lalupur
Gram Panchayat: Lalupur Block: Mohammadabad
District: Ghazipur State: Uttar Pradesh
Address: Remarks:
Latitude: Longitude:

Date & time of sample collection

05.02.2024 | 03:26:00 PM

Date & time of sample received in lab

06.02.2024 | 11:38:00 PM

Date & time of sample analysed

08.02.2024 | 12:19:00 PM

Date & time of report generation

08.02.2024 | 01:18:05 PM


Test results

| Sr. No. | Parameters tested | Unit of measurement | Requirement (acceptable limit) as per BIS 10500 | Permissible limit (in absence of alternate source) as per BIS 10500 | Test result value | Remarks |
|---------|--|--|---|---|-------------------|---------|
| 1 | Chloride (as Cl)* | mg/l | 250 | 1000 | 84.970 | |
| 2 | Colour | Hazan units | 5 | 15 | 6.000 | |
| 3 | Conductivity | micromhos per centimeter / microsiemens per centimeter | NA | NA | 820.000 | |
| 4 | E. coli | CFU/100 ml | Shall not be detectable in any 100 ml sample | No Relaxation | 0.000 | |
| 5 | Fluoride (as F) | mg/l | 1 | 1.5 | 1.100 | |
| 6 | Free residual Chlorine | mg/l | 0.2 | 1 | 0.020 | |
| 7 | Iron (As Fe) | mg/l | 1 | No Relaxation | 0.200 | |
| 8 | Nitrate (as NO ₃) | mg/l | 45 | No Relaxation | 25.000 | |
| 9 | pH* | NA | 6.5-8.5 | No Relaxation | 7.060 | |
| 10 | Sulphate (as SO ₄) | mg/l | 200 | 400 | 49.000 | |
| 11 | TDS* | mg/l | 500 | 2000 | 523.000 | |
| 12 | Total Alkalinity (as Calcium Carbonate)* | mg/l | 200 | 600 | 180.000 | |
| 13 | Total coliform | CFU/ 100 ml | Shall not be detectable in any 100 ml sample | No Relaxation | 0.000 | |
| 14 | Total Hardness (As CaCO ₃)* | mg/l | 200 | 600 | 448.000 | |
| 15 | Turbidity* | NTU | 1 | 5 | 3.640 | |

Note:

- 1)*Indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

***** This is an electronically generated report and does not require a signature.*****


 Authorised signatory
 Beena Ambika (Test Lab Incharge)

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.